

ADDENDUM NUMBER : 1

Page 1 of 1
Date: 7/29/16

The Housing Development Division of the City of Colorado Springs

Owners: Nellene Pine

RFQ Opening Date: August 12,2016

Address: 2141 Friendship Pl

Quote No.: 16-014RO

This document shall become as fully a part of the above named Contract Documents as if included and shall take full and complete precedence over anything stated or shown to the contrary in them.

Each and every respondent, subcontractor and material supplier shall be responsible for reading each and every item in this Addendum to ascertain the extent and manner it affects the work in which he/she is interested.

Acknowledge receipt of Addendum on the Request for Quote and indicate any changes in the base proposal.

The contractor is directed to make the following changes to the work description for the above referenced property:

Extend Quote Due date to Friday, August 12th, 2016 at 2 PM.

Item #2-Concrete-include replacing stoop which is sinking and severely sloped, approx. 3'-6" X 3'-6" x 8 inches thick. Riser height to meet code, max 7 ¾ inches. Mechanically compact soil before replacement.

Item #8-Painting-Clarification, substitute "exterior" for "interior".

Item #16-Painting-Include painting kitchen ceiling and soffit and wood base trim in kitchen. Paint base shoe to match.

Nellene Pine

Date

Date

For City: Deane Robertson

Date: